
DRAWING #	SH.	REV.	DESCRIPTION	DATE	BY	EN #
NGC02	1					




## SPECIFICATIONS:


1-THE EXTERIOR COATING SHALL HAVE A THICKNESS RANGE
OF 4 MILS TO 6 MILLS WITH 5 MILS BEING NOMINAL.
2-THE INTERIOR COATING SHALL HAVE A THICKNESS RANGE
OF 1.5 MILS TO 3 MILS WITH 2.0 MILS BEING NOMINAL.
3-ALL THREAD SHALL HAVE AT LEASE 5 THREADS UNCOATED
TO ASSURE A PROPER GROUND.

## NOTES:

- -RIGID GALVANIZED CONDUIT AND FITTING CONFORM TO UL STANDARD 6 AND STANDARD 514B.
- -A POLYURETHANE COATING SHALL BE UNIFORMLY AND CONSISTENTLY APPLIED
   TO THE INTERIOR AND EXTERIOR OF ALL CONDUIT AND FITTINGS.

   -THE INTERIOR AND EXTERIOR POLYURETHANE COATING APPLIED TO THE CONDUIT.
- -THE INTERIOR AND EXTERIOR POLYURETHANE COATING APPLIED TO THE CONDU AND FITTINGS SHALL HAVE SUFFICIENT FLEXIBILITY TO PERMIT FIELD BENDING WITHOUT CRACKING OR FLAKING AT TEMPERATURES ABOVE 30°F (-1°C).
- -TRADE SIZE PIPE FROM 3/4" TO 6"





	UNLESS OTHERWISE SPECIFIED USE: NOTICE:			NOTICE:	MODE		TITLE: GAL VANIZED COATED RIGID CONDUIT		7 SCALE: NTS		DATE: 05.06.10		CAT. # <sub>NGCO2</sub>	
	TOLERANCES OF DIMENSIONS THIS DRAWING AND THE INFORMATION IT DISCLOSES IS THE EXCLUSIVE				NULLU INU.		SPECIFICATIONS — TUNNEL		DWN. BY: + ir		CH'K. BY:		DWG. #	
PRACTICES	2 DEC.	PROPERTY OF NCEEC, ANY REPRODUCTION OR USE OF THIS DRAWING IN WHOLE OR IN PART WITHOUT THE		367 Bay Shore Road	Phone: (800)759-7856			tjr				"		
			±0°30'	EXPRESS CONSENT OF NCEEC INC. IS PROHIBITED.	Deer Park, NY 11729	Fax: (631)586-5556	ORDER # .	TYPE: .	SHEET 1 OF 1	SHEET	. IS .	SIZE	NGC02	